



Number	KIP-16379/G	Replaces	KIP-15927/G
Issue date	30-08-2019	Contract number	I 6700
Due date	29-08-2029	Scope	(EU) 2016/426 (9 March 2016)
Report number	2002750/1	Module	B (Type testing)
PIN	0476CT2750		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the Central heating condensing boilers, type(s):

**VICTRIX KW TT, VICTRIX KW TT PLUS,
VICTRIX MAIOR TT, VICTRIX MAIOR TT PLUS**

Manufacturer

Immergas S.p.A.
Via Cisa Ligure, 95,
42041 Brescello (RE), Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2012+A1:2015, EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadrano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755
Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it
www.kiwacermet.it

GASTEC

Chief Operating Officer
Giampiero Belcredi

Firmato digitalmente da:BELCREDI GIAMPIERO
Data:04/09/2019 10:21:40



Number KIP-16379/G **Page** 1 of 1
Issue date 30-08-2019 **Scope** (EU) 2016/426 (9 March 2016)
Due date 29-08-2029 **Module** B (Type testing)
Report number 2002750/1
PIN 0476CT2750

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name:
Immergas

Types:

Model name	Heat Input (Hi)	
	CH Max – Min (kW)	DHW Max – Min (kW)
VICTRIX 12 KW TT PLUS	12,3 – 2,0	12,3 – 2,0
VICTRIX MAIOR 28 TT	24,9 – 2,9	29,1 – 2,9
VICTRIX 28 KW TT	24,9 – 2,9	29,1 – 2,9
VICTRIX 24 KW TT PLUS	24,9 – 2,9	29,1 – 2,9
VICTRIX MAIOR 35 TT	34,9 – 3,6	34,9 – 3,6
VICTRIX MAIOR 35 PLUS TT	34,9 – 3,6	34,9 – 3,6
VICTRIX 35 KW TT	32,7 – 4,0	34,9 – 4,0
VICTRIX 32 KW TT PLUS	32,7 – 4,0	34,9 – 4,0

Appliance types:

B23P, B33, B53, C13, C33, C43, C53, C63, C83, C93, C13X, C33X, C43X, C83X, C93X

Countries:

AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:

Group	mbar	Group	mbar	Group	mbar	Group	mbar
E	20	Er	20/25	Lw	20	P	30;37;50
H	20	E(S)	20	Ls	13		
Esi	20/25	E(R)	20	M	20		

The above gas groups can be combined according to the standard EN437:2018 and national situation of countries.

Remarks:

The installation types C63, C13X, C33X, C43X, C83X, C93X are valid only for the appliances VICTRIX 28 KW TT and VICTRIX 35 KW TT

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

CERTIFICATE



Number	KIP-15927/E	Replaces	—
Issued	09-05-2018	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	2002750	Page	1 of 2
PIN	0476CT2750		

EC TYPE EXAMINATION CERTIFICATE

Kiwa Cermet Italia, notified body for council Directive 92/42/EEC, hereby declares that according to article 4 of commission regulation (EU) No. 813/2013 the products

Central heating condensing boilers

Trade mark: **Immergas**
Models: VICTRIX 12 KW TT PLUS, VICTRIX 24 KW TT PLUS, VICTRIX MAIOR 28 TT, VICTRIX 28 KW TT, VICTRIX MAIOR 35 TT, VICTRIX MAIOR 35 TT PLUS, VICTRIX 35 KW TT, VICTRIX 32 KW TT PLUS
as specified in the Annex 1

Placed on the market by **Immergas S.p.A.**
Via Cisa Ligure, 95,
42041 Brescello (RE), Italy

Have achieved the following (see Annex 1) full and part load efficiencies.

The assessment test have been performed using the following standards as guidelines:

EN 15502-1:2012+A1:2015
EN 15502-2-1:2012+A1:2016

*The validity of this certificate can be verified on request at the following e-mail address: info@kiwa.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive, as well as on updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia*

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)


Tel +39. 0438 411755
Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it
www.kiwacermet.it

GASTEC

Chief Operating Officer
Giampiero Belcredi



Organismo Notificato n. 0476

SGQ N° 007A
SGA N° 010D
PRD N° 069B
FSM N° 004I
PRS N° 089C

Rev.8



Number	KIP-15927/E	Replaces	—
Issued	09-05-2018	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	2002750	Page	2 of 2
PIN	0476CT2750		

EC TYPE EXAMINATION CERTIFICATE

ANNEX 1

Models:

	VICTRIX 12 KW TT PLUS	VICTRIX MAIOR 28 TT VICTRIX 28 KW TT VICTRIX 24 KW TT PLUS
η_{100}	98,0 %	97,2 %
η_{30}	109,0 %	108,3 %
η_4	88,2 %	87,5 %
η_1	98,2 %	97,5 %
P_4	12,0 kW	24,0 kW
P_1	n.t	n.t
C.Heater?	No ⁽¹⁾	No ⁽¹⁾
B ₁ Boiler?	No	No
Type of boiler:	"Condensing"	"Condensing"

⁽¹⁾ The boiler can be connected to an external tank for the domestic hot water production

	VICTRIX MAIOR 35 TT, VICTRIX MAIOR 35 TT PLUS VICTRIX 35 KW TT, VICTRIX 32 KW TT PLUS
η_{100}	97,9 %
η_{30}	108,5 %
η_4	88,2 %
η_1	97,7 %
P_4	34,2 kW
P_1	n.t
C.Heater?	No ⁽¹⁾
B ₁ Boiler?	No
Type of boiler:	"Condensing"

Note:

η_{100} = At rated heat output and high-temperature regime - NCV (*)
 η_{30} = At 30 % of rated heat output and low-temperature regime - NCV (**)
 η_4 = At rated heat output and high-temperature regime - GCV (*)
 η_1 = At 30 % of rated heat output and low-temperature regime - GCV (**)
 P_4 = At rated heat output and high-temperature regime (*)
 P_1 = At 30 % of rated heat output and low-temperature regime (**)
 C.Heater = Combination heater (Yes = with domestic hot water production / No = Heating system only)
 B₁ Boiler = B₁ according CEN/TR 1749:2014
 Type of boiler = "Condensing Boiler" or "Low Temperature Boiler" or "Other Boiler"

Efficiency's values have been measured with gas G20.

(n.t. = not tested)

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

CERTIFICATE

Kiwa Cermet Italia S.p.A.
 Società con socio unico, soggetta all'attività di
 direzione e coordinamento di Kiwa Italia
 Holding Srl

Via Cadrano, 23
 40057 Granarolo dell'Emilia (BO)

Unità locale
 Via Treviso 32/34
 31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

G A S T E C